

**Addendum No. 1, dated November 8, 2007, to Bidding Documents for Replace Rethermalization and Other Kitchen Equipment at Seven (7) Facilities Statewide in Virginia, Plans and Specifications dated October 26, 2007, K♦B File No. 07008, Project Code: 720-07720-01.**

**TO: PLAN HOLDERS OF RECORD**

**FROM: KINCAID ♦ BRYANT, Consulting Engineers  
725 Church Street, 7<sup>th</sup> Floor  
Allied Arts Building  
Lynchburg, VA 24504**

---

***This Addendum forms a part of the Contract Documents and modifies the Plans and Specifications dated October 26, 2007, as noted below. Acknowledge receipt of this Addendum on the Bid Form. Failure to do so may subject Bidder to disqualification.***

---

## **GENERAL**

1. See attached Pre-Bid Conference Agenda, Pre-Bid Attendance List, Site Visit Schedule and Plan Holders List.

## **DRAWINGS**

### General:

1. Provide new refrigerant suction and liquid line piping at all locations in lieu of notes that indicate piping is to be reused.
2. In the Food Service Equipment Schedules, change the "7.75" and 9" Plates diameters" to read "7.75" and 9" plate diameters".

**END OF ADDENDUM NO. 1**